

QA Testing Laboratories Pvt. Ltd.

(Govt. Approved Testing Laboratories)

B-76, Sector-64, Gautam Buddha Nagar, Noida-201301 (Uttar Pradesh)

Tel.: +91-120-4133953 • Mobile: +91-8287945370 • E-mail: admin@qatestinglaboratories.com

Website : www.qatestinglaboratories.com

CIN : U51100UP2018PTC108293 • GSTIN : 09AAACQ5609C1ZN

IAS-ANZ



An ISO 9001:2015, 14001:2015, 45001:2018 & ISO/IEC 17025:2017 Accredited & BIS Recognised Laboratory



TEST CERTIFICATE

(This Certificate is not Valid without Hologram)

Test Report No : QAL/WT/251018001206 Issue Date : 23/10/2025
Sample Name : Drinking Water Sample Received On : 18/10/2025
Sample Code : - Reference No : 3420/703/17
Issued To : OFFICE OF EXECUTIVE ENGINEER Sampling Date : 17/10/2025
CONSTRUCTION DIVISION UTTARAKHAND Sampling Quantity : 2 Ltr.
PEYJAL NIGAM BHIMTAL (NAINITAL). Letter Date : 16/10/2025
Date of Mfg. : NS
Name of Scheme : Distt.-Nainital Sainik School Khorakhal Pumping Peyjal Yojna Date of Exp. : NS
Sample Description : Physical, Chemical & Bacteriological Analysis of Water sample Date of Starting : 18/10/2025
Name of Source : District-Nainital Block-Ramgarh Curgudi Source Date of Completion : 23/10/2025

S.No.	Test Parameter	Units	Results	Specification as per IS:10500:2012		Test Method
				Acceptable Limit	Permissible Limit	
1	Color	Hazen	1	5 max.	15 max.	IS : 3025(P-4)
2	Odour	-	Agreeable	Agreeable	Agreeable	IS : 3025(P-5)
3	Taste	-	Agreeable	Agreeable.	Agreeable	IS : 3025 (P-7 & 8)
4	Turbidity	NTU	<1	1 max.	5 max.	IS : 3025(P-10)
5	pH value at 25°C	-	7.12	6.5-8.5	No Relaxation	IS : 3025 (P-11)
6	Total Hardness as CaCO ₃	mg/l	168	200 max	600 max.	IS : 3025 (P-21)
7	Iron (as Fe)	mg/l	0.084	1 max	No Relaxation	IS : 3025 (P-53)
8	Chloride (as Cl)	mg/l	8.86	250 max.	1000 max.	IS : 3025 (P-32)
9	Fluoride (as F)	mg/l	0.077	1 max.	1.5 max.	IS : 3025 (P-60)
10	Total Dissolved Solid (TDS)	mg/l	322	500 max.	2000 max.	IS : 3025 (P-16)
11	Total Coliform Bacteria	MPN/10 0 ml	Absent	Shall not be detectable in any 100 ml sample	Shall not be detectable in any 100 ml sample	IS : 1622
12	E coli	MPN/10 0 ml	Absent	Shall not be detectable in any 100 ml sample	Shall not be detectable in any 100 ml sample	IS : 1622

SAMPLE COLLECTED BY US

End of Report

Upendra Kumar

Authorized Signatory (Sign & Stamp):

Dinesh Kumar

Quality Manager

Approved By (Sign & Stamp):

Note: a) This report is not reproduced wholly or in partially and forbidden to be used as an evidence in the court of law and ought not to be used in any advertisement media without our special permission in writing. b) The data reported in this TEST CERTIFICATE are valid at the time of and under the stipulated conditions of measurement and the test results are applicable to those items of product which have been tested and do not apply to the other products even though declared to be identical. c) Except by special arrangement, the test items will not be retained by the company not more than one month. d) Report refers to the sample received by M/s QA Testing Laboratories Pvt. Ltd. e) This report is valid for the tested sample only.

Format No. QA/TC/002

Page : 1 of 1